

THE CITY OF WALTHAM
MASSACHUSETTS

PURCHASING DEPARTMENT

Waltham High School AC Replacement

ADDENDUM NO. 2

February 13, 2013

CHANGES, CORRECTIONS AND CLARIFICATIONS

The attention of bidders submitting proposals for the above subject project is called to the following addendum to the specifications. The items set forth herein, whether of omission, addition, substitution or clarification are all to be included in and form a part of the proposal submitted.

THE NUMBER OF THIS ADDENDUM (NO. 2) MUST BE ENTERED IN THE APPROPRIATE SPACE PROVIDED in the PRICE SHEET.

ITEM NO.: 1 ANSWERS TO POSED QUESTIONS

Q1. Is the City looking for a compressor/chiller with a 160 nominal tons that will produce 139 tons at ARI conditions and a remote condensing Unit.?

A1. Yes the City is looking for a 160 nominal unit producing 139 tons with a remote condensing unit. A Wye Delta Starter is required on the chiller. The specs require a factory installed attenuator.

ITEM NO.: 2 POSTPONEMENT OF BID OPENING DATE

The bid due date (bid opening date) is Postponed to **Tuesday February 19, 2013 at 10 AM.** The location of the bid opening remains the same: Purchasing Department, City Hall, 610 Main Street Waltham 02452

END OF ADDENDUM 2