

THE CITY OF WALTHAM
MASSACHUSETTS
PURCHASING DEPARTMENT

Building Management Control System,
School Department

ADDENDUM NO. 1

Oct. 8, 2015

CHANGES, CORRECTIONS AND CLARIFICATIONS

The attention of bidders submitting proposals for the above subject project is called to the following addendum to the specifications. The items set forth herein, whether of omission, addition, substitution or clarification are all to be included in and form a part of the proposal submitted.

THE NUMBER OF THIS ADDENDUM (NO. 1) MUST BE ENTERED IN THE BID PRICE SECTION

ITEM 1: ANSWERS TO POSED QUESTIONS.

Q1. Page 5 of the Bid PDF states that the School wishes to purchase 81 Aruba AP 105 Wireless Access Point. Please clarify if in fact this is the case

A1. Please ignore this statement

Q2. Part 1 of the specification states that The Contractor shall have a minimum of 5 years of experience in the sales, installation, engineering, programming, servicing, and commissioning of Niagara AX. Please confirm that this restricts the bids to qualified contractors whose date of incorporation is earlier than 10/23/10.

A2. The City is confirming the statement.

Q3. Per specification 2.1-E, systems besides Facility Explorer by Johnson Controls are acceptable per addendum. Is a Siemens system based on the NiagaraAX platform acceptable?

A3. Yes a Siemens Niagara AX platform is acceptable.

End of Addendum 1