

THE CITY OF WALTHAM  
MASSACHUSETTS

PURCHASING DEPARTMENT  
**CASTINGS AND PIPES, 2016**

**ADDENDUM NO. 1**

June 7, 2016

**CHANGES, CORRECTIONS AND CLARIFICATIONS**

The attention of bidders submitting proposals for the above subject project is called to the following addendum to the specifications. The items set forth herein, whether of omission, addition, substitution or clarification are all to be included in and form a part of the proposal submitted.

THE NUMBER OF THIS ADDENDUM (NO. 1) MUST BE ACKNOWLEDGED IN THE PAGE FOLLOWING THE "SPECIFICATION" HEADER PAGE

---

**ITEM 1: ANSWERS TO POSED QUESTIONS**

**Q 1.** What size line item numbers 10 & 11 are supposed to be

10.	Compression Adaptor - ( <b>Mueller</b> ) - H-15428N	100
11.	Compression Adaptor - ( <b>Mueller</b> ) - H-15451N	100

**A 1.** Part #10 – Is 1" x ¾" Mueller Compression Adaptor (MIP thread)  
Part #11 – Is 1" x ¾" Mueller Compression Adaptor (FIP thread)

**End of Addendum 1**