

THE CITY OF WALTHAM  
MASSACHUSETTS

PURCHASING DEPARTMENT

**CROSS WALK LIGHT INSTALLATION AT FALZONE PARK**

**ADDENDUM NO. 1**

May 6, 2016

**CHANGES, CORRECTIONS AND CLARIFICATIONS**

The attention of bidders submitting proposals for the above subject project is called to the following addendum to the specifications. The items set forth herein, whether of omission, addition, substitution or clarification are all to be included in and form a part of the proposal submitted.

THE NUMBER OF THIS ADDENDUM (NO. 1) HAS TO BE RECOGNIZED AS RECEIVED BY THE COMPANY ON IN THE PRICE SHEET PAGE

---

**ITEM 1: ANSWERS TO POSED QUESTIONS**

**Q1.** What AASHTO criteria shall be used for the mast arm? What is the size of the mast arm foundation?

**A1.** The mast arm and its foundation shall be designed meet the requirements for 90 mph wind, in accordance with AASHTO.

**Q2.** The drawing on page 38 of 51 of the bid documents don't match the totals listed on page 24 of 51. Please clarify.

**A2.** The correct information is on page 24. The drawing is a quick rendering of the project.

**End of Addendum 1**