

THE CITY OF WALTHAM  
MASSACHUSETTS

PURCHASING DEPARTMENT

**DESIGN OF FIRE SUPPRESSION SYSTEMS**

**ADDENDUM NO. 1**

October 31, 2017

**CHANGES, CORRECTIONS AND CLARIFICATIONS**

The attention of bidders submitting proposals for the above subject project is called to the following addendum to the specifications. The items set forth herein, whether of omission, addition, substitution or clarification are all to be included in and form a part of the proposal submitted.

THE NUMBER OF THIS ADDENDUM (NO. 1) MUST BE ACKNOWLEDGED IN THE PRICE SHEET

---

**ITEM 1: ADD SPECIFICATIONS**

**In the Scope of Service Section, Attachment "A" ADD the following:**

The selected designer shall provide analysis of any existing fire signaling system in each of the buildings specified and provide details and designs to integrate both the new fire suppression system signaling with occupant notification in to an addressable panel. Where no fire signaling or fire alarm notification system is present, the selected designer will provide a design for a new fire signaling system, which may include, but not be limited to strobes, detectors (heat, smoke and CO), addressable panels, central signaling, pull stations and specifications for monitoring. All specifications shall be designed in accordance with 780 CMR 9.00 of the ninth edition of the State Building Code.

**End of Addendum 1**