

THE CITY OF WALTHAM
MASSACHUSETTS

PURCHASING DEPARTMENT

**ROADWAY AND TRAFFIC SIGNAL IMPROVEMENT PROJECT,
TRAPELO ROAD AND FOREST STREET**

ADDENDUM NO. 1

Nov. 27, 2011

CHANGES, CORRECTIONS AND CLARIFICATIONS

The attention of bidders submitting proposals for the above subject project is called to the following addendum to the specifications. The items set forth herein, whether of omission, addition, substitution or clarification are all to be included in and form a part of the proposal submitted.

THE NUMBER OF THIS ADDENDUM (NO. 1) MUST BE ON PAGE 16, SECTION 00300-FORM FOR GENERAL BID-PARAGRAPH "A".

ITEM NO.: 1 ANSWERS TO POSED QUESTIONS

Q1. We have observed the furnishing and installing of 4' x 5' tree grates cast into the sidewalks. Please advise how these will be paid under the contract and the specified type of material.

A1. Provide 4'x5' tree pits not grates. We are not proposing any cast in grates, simply to form the concrete sidewalk and allow a 4'x5' opening. It does not require any additional items to be furnished or installed or any additional specifications

Q2. With regards to bid item #222.3 "Frame and Grate (or Cover)", the bid item calls for a quantity of 55 units, with the exception of the new structures being provided we cannot find where the balance of the item will be used.

A1. The intent of the project is to replace any Frame and Grate (or Cover) that is being adjusted. Therefore, there are 10 new structures (CB) as well as 45 structures to be adjusted: 25 Drainage Structures Adjusted, 3 Drainage Structures (Change in Type), 16 Sanitary Structures Adjusted and 1 Sanitary Structure Remodeled. (10+25+3+16+1=55)

END OF ADDENDUM 1