

THE CITY OF WALTHAM
MASSACHUSETTS
PURCHASING DEPARTMENT

Hardy Apartments Re-Roofing and Exterior Repairs, 2019

ADDENDUM NO. 1

August 21, 2019

CHANGES, CORRECTIONS AND CLARIFICATIONS

The attention of bidders submitting proposals for the above subject project is called to the following addendum to the specifications. The items set forth herein, whether of omission, addition, substitution or clarification are all to be included in and form a part of the proposal submitted.

THE NUMBER OF THIS ADDENDUM (NO. 1) MUST BE ACKNOWLEDGED IN SECTION FORM FOR GENERAL BID.

ITEM 1: ANSWERS TO POSED QUESTIONS

***Q1.** 075323 specifies both a cover board and a vapor barrier. However, this job consists of new insulation and EPDM over existing insulation, which means the existing poly VB remains. Also, none of the details show a cover board. Please confirm whether either of these products is required*

***A1.** Neither the coverboard nor the Vapor Barrier is required except in the case where the existing vapor barrier or coverboard is removed.*

End of Addendum 1