

THE CITY OF WALTHAM
MASSACHUSETTS

PURCHASING DEPARTMENT

**Purchase of Air Cooled Self Contained AC Unit for the Vault Project
at the Former Bright School**

ADDENDUM NO. 1

November 1, 2011

CHANGES, CORRECTIONS AND CLARIFICATIONS

The attention of bidders submitting proposals for the above subject project is called to the following addendum to the specifications. The items set forth herein, whether of omission, addition, substitution or clarification are all to be included in and form a part of the proposal submitted.

THE NUMBER OF THIS ADDENDUM (NO. 1) MUST BE ENTERED IN ANY BLANK SPACE IN THE BID PRICE SHEET.

ITEM NO.: 1 ANSWERS TO POSED QUESTIONS

Q. What is the voltage? The options are 208/1/60 or 277/1/60.

A. Voltage is 208/1/60.

Q. Is this unit ducted? We can either supply a filter box for ducted applications or a supply/return grill that would fit into a 2x4 ceiling grid if not ducted.

A. Unit is ducted.

Q. The spec mentions electric reheat, scr electric reheat and hot gas reheat. Which one would they like?

A. Scr electric reheat is preferred.

Q. The spec mentions a remote temperature sensor. The unit will normally sense temperature in the wall mounted controller. Do they really want a separate remote temperature sensor?

A. There is no need for a separate remote temperature sensor. The wall mounted thermostat is fine.