

THE CITY OF WALTHAM
MASSACHUSETTS
PURCHASING DEPARTMENT

CITY-WIDE LEAK DETECTION SURVEY

ADDENDUM NO. 1

April 16, 2015

CHANGES, CORRECTIONS AND CLARIFICATIONS

The attention of bidders submitting proposals for the above subject project is called to the following addendum to the specifications. The items set forth herein, whether of omission, addition, substitution or clarification are all to be included in and form a part of the proposal submitted.

THE NUMBER OF THIS ADDENDUM (NO. 1) MUST BE ENTERED IN THE PROVIDED SPACE OF THE BID PRICE SECTION

ITEM 1: ANSWERS TO POSED QUESTIONS

Q1.What is the average system pressure?

A1. The average system pressure, low pressure service area = 70 psi, high pressure service area = 110 psi

Q2. What if valves are not accessible?

A2. City has dimensions to gate vales that will be provided to contractor for finding buried gates, if necessary

Q3. Please confirm the following is correct, and if not please explain: The company who is awarded the contract is to survey the approximate 175 miles in 60 days of receiving the notice to proceed and then will have the option of having this survey completed again each year for a total of two additional years

A3. Survey approximately 175 miles on pipe annually

Q4. What material are the service pipes?

A4. Pipe material is predominately cast iron, with newer mains being ductile iron pipe.

Q5. Is this program being funded by SRF?

A5. *No, the funding is from the City's operating funds*

ITEM 2: DELETE AND REPLACE

DELETE the price sheet, page 37 (last Page) **and REPLACE** with the one attached here.

End of Addendum 1

**Price Sheet
Three (3) Years**

A. City-Wide Leak Detection Survey:

A Year 1 \$ _____ per mile; \$ _____ per Linear Foot

Year 2 \$ _____ per mile; \$ _____ per Linear Foot

Year 3 \$ _____ per mile; \$ _____ per Linear Foot

A1. TOTAL \$ _____ per mile; \$ _____ per Linear Foot

THE BASE OF THE AWARD, ASIDE FROM EXPERIENECE AND TECHNICAL ABILITY, IS BASED ON THE TOTAL OF A1 AND THE AVERAGE OF THE 3 YEAR LINEAR FOOT BID.

My company acknowledges receipt of addenda number : _____, _____, _____, _____, _____

Company Name: _____

Authorized Signature: _____

Print name: _____, Date: _____

Company Email Contact: _____