

THE CITY OF WALTHAM
MASSACHUSETTS

PURCHASING DEPARTMENT

LOGAN PARK IMPROVEMENTS

ADDENDUM NO. 1

June 27, 2011

CHANGES, CORRECTIONS AND CLARIFICATIONS

The attention of bidders submitting proposals for the above subject project is called to the following addendum to the specifications. The items set forth herein, whether of omission, addition, substitution or clarification are all to be included in and form a part of the proposal submitted.

THE NUMBER OF THIS ADDENDUM (NO. 1) MUST BE ENTERED IN THE APPROPRIATE SPACE OF SECTION 00300" FORM FOR GENERAL BID".

ITEM NO.: 1 **ADD ITEM**

SECTION 02540 PLAYGROUND SURFACING & CURBING

Section 2.03 PRECAST CONCRETE CURBING

Add Subparagraph E as follows:

"E. Where ends of curbing meet at other than a 90 degree angle, as in the new play area, curbing shall be custom manufactured to the required angle in order to produce a tight joint, with parallel edges.

One source of custom manufactured concrete curbing is Precast Specialties, Abington, MA.

END OF ADDENDUM 1