

THE CITY OF WALTHAM  
MASSACHUSETTS

PURCHASING DEPARTMENT

**MacArthur School Playground Construction**

**ADDENDUM NO. 1**

October 4, 2017

**CHANGES, CORRECTIONS AND CLARIFICATIONS**

The attention of bidders submitting proposals for the above subject project is called to the following addendum to the specifications. The items set forth herein, whether of omission, addition, substitution or clarification are all to be included in and form a part of the proposal submitted.

THE NUMBER OF THIS ADDENDUM (NO. 1) MUST BE ACKNOWLEDGED IN THE BID FORM - SECTION 00 41 13 (B).

---

**ITEM 1: CHANGES**

Add the following notes to **Drawing L3**, Layout & Materials Plan:

1. **REPLACE** the horizontal dimensions of the Concrete Walk between the existing circular play area and the proposed play area as follows:

Connection at the circular play area, change from 10' to 16'. Connection at the proposed play area. **Change** from 14' to 22'. **Revise** the Note referring to the sections to be removed to 3 in place of 2 sections.

2. In the paved area south and adjacent to the building **relocate** the two proposed basketball goals from the south side of the paved area to the east side and move the "home plate" of the kickball court north 10' towards the building.

**These changes are to be included on drawing L4, Grading & Drainage Plan.**

**End of Addendum 1**