

THE CITY OF WALTHAM  
MASSACHUSETTS

PURCHASING DEPARTMENT

**PURCHASE AND INSTALLATION OF INTERACTIVE PROJECTORS,  
WALTHAM SCHOOL DISTRICT**

**ADDENDUM NO. 1**

March 27, 2012

**CHANGES, CORRECTIONS AND CLARIFICATIONS**

The attention of bidders submitting proposals for the above subject project is called to the following addendum to the specifications. The items set forth herein, whether of omission, addition, substitution or clarification are all to be included in and form a part of the proposal submitted.

THE NUMBER OF THIS ADDENDUM (NO. 1) MUST BE ENTERED IN THE BLANK SPACE AT THE END OF THE PRICE SHEET.

**ITEM NO.: 1**      **ANSWERS TO POSED QUESTIONS**

**Q1.** Is there a walk through date so that we can look at the locations and types of rooms the projectors will be installed in?

**A2.** The Vendor walkthroughs is scheduled for Wednesday, April 4, 2012 meet at the Waltham High School at 1:00 PM; Kennedy Elementary 2:00 PM; North East Elementary 3:00 PM and McDevitt School 4:00 Pm.

**Q2.** Is the vendor providing all cabling from the projector to the wall plate?

**A2.** Yes, all cabling is to be provided by the Vendor.

**Q3.** What types of connections are needed on the wall plate? VGA, HDMI, 3.5mm, USB (USB and VGA are a must in order to connect PC/ Laptop to projector)

**A3.** See attached Drawing.


**Q4.** Is Raceway allowed or must all cables be fished properly through walls?

**A4.** All Cables must be fished properly through walls.

**Q5.** What is the average distance from the projector to the wall plate?

**A5.** The cable runs should be 30' or less to avoid signal loss.

# PROJECTOR WALL PLATE INTERFACE



\* DB15 FEMALE ACCEPTS SIGNAL FROM ALL  
VGA - SVGA - WXGA etc - PROJECTOR AUTO DETECTS  
RESOLUTION & INPUT CHANNEL.

Michel P. Iodice 3-27-2012