

THE CITY OF WALTHAM
MASSACHUSETTS
PURCHASING DEPARTMENT

**RECONSTRUCTION OF SPRUCE STREET
AND WALNUT STREET PARKING LOTS**

ADDENDUM NO. 1

Nov. 19, 2014

CHANGES, CORRECTIONS AND CLARIFICATIONS

The attention of bidders submitting proposals for the above subject project is called to the following addendum to the specifications. The items set forth herein, whether of omission, addition, substitution or clarification are all to be included in and form a part of the proposal submitted.

THE NUMBER OF THIS ADDENDUM (NO. 1) MUST BE ENTERED PAGE 3-1 FORM FOR GENERAL BID

ITEM 1: ANSWERS TO POSED QUESTIONS

Q1. What Redi Rock system is being specified? 28" blocks with caps, 41" blocks with caps, or 60" blocks with caps. Is the footing stone or concrete?

A1. The 28" Redi Rock blocks with caps are the size we are looking for. The type of footing is up to the discretion of the Contractor.

Q2. Where do I find the Equal Opportunity Certification Form? I could not find it in the specs.

A2. The Equal Opportunity Certification Form will be provided upon the execution of the contract

Q3. How is the parking lot demo to be handled? Can we crush the existing bituminous concrete and use it and the existing base for the base for the new surfacing, or do we have to excavate and dispose of the existing bituminous concrete and base material and supply new base material. There does not seem to be an item for base material for the parking lots.

A3. Either option for paving the lots is acceptable – either crushing the existing bituminous concrete for use for the base of the new surfacing, or excavation and disposal of the existing bit conc and using new base material. It is the discretion of the Contractor.

End of Addendum 1