

THE CITY OF WALTHAM
MASSACHUSETTS
PURCHASING DEPARTMENT

Cedarwood Water Storage Tank Rehabilitation Project

ADDENDUM NO. 2

February 5th, 2024

CHANGES, CORRECTIONS AND CLARIFICATIONS

The attention of bidders submitting proposals for the above subject project is called to the following addendum to the specifications. The items set forth herein, whether of omission, addition, substitution, or clarification are all to be included in and form a part of the proposal submitted.

THE NUMBER OF THIS ADDENDUM (NO. 2) MUST BE ACKNOWLEDGED IN SECTION 00300 – BID FORM.

ITEM 1: ANSWERS TO POSED QUESTIONS

Q1. The spec for the fencing is a combo of mesh panels and chain link fence. We're assuming the chain link matches the tank and need to know the size of the fabric, 2" is common.

A1. Fencing is 358 Welded Wire Mesh, not chain link. For mesh size, refer to Specification Section 02834, paragraph 2.2.A.5 - Mesh size: 12.7x76.2 mm to 25x75 mm (1/2" x 3").

Q2. On the bid submission checklist, a "Prevailing Wage Certificate" is included as being required but there isn't one in the specifications. Will one be provided?

A2. Prevailing Wage Certificate is represented on Page 23-24 for reference only. Nothing is required to be submitted for this item.

End of Addendum 2