

THE CITY OF WALTHAM
MASSACHUSETTS

PURCHASING DEPARTMENT

GENERATOR REPLACEMENT, PUMP STATION #2 AT 356 SECOND AVENUE

ADDENDUM NO. 2

August 16, 2012

CHANGES, CORRECTIONS AND CLARIFICATIONS

The attention of bidders submitting proposals for the above subject project is called to the following addendum to the specifications. The items set forth herein, whether of omission, addition, substitution or clarification are all to be included in and form a part of the proposal submitted.

THE NUMBER OF THIS ADDENDUM (NO. 1) MUST BE ENTERED IN THE SECTION 004113 - BID FORM – STIPULATED SUM

ITEM NO.: 1 ANSWER TO POSED QUESTION

Q1. Is back up power needed during the period between removal and installation of the generator?

A1. The Second Avenue wastewater pump station must be operational at all times for public safety. The station cannot be without power at any time. Therefore, the contractor shall provide any equipment necessary to ensure that back-up power is available for the duration of the project.”

Q2. Is the contractor responsible for removing the old generator?

A2. The contractor is responsible for the removal and disposal of the old generator.

End of Addendum 1