

THE CITY OF WALTHAM  
MASSACHUSETTS

PURCHASING DEPARTMENT

**Glycol Replacement At the Kennedy Middle School**

**ADDENDUM NO. 2**

May 28, 2013

**CHANGES, CORRECTIONS AND CLARIFICATIONS**

The attention of bidders submitting proposals for the above subject project is called to the following addendum to the specifications. The items set forth herein, whether of omission, addition, substitution or clarification are all to be included in and form a part of the proposal submitted.

THE NUMBER OF THIS ADDENDUM (NO. 2) MUST BE ENTERED IN THE APPROPRIATE SPACE PROVIDED IN THE PRICE SHEET FORM.

**ITEM NO.: 1    ANSWERS TO POSED QUESTIONS**

**Q1. What are the addresses of the two schools?**

**A1. Kennedy Middle is 655 Lexington Street Waltham Ma 02452, Stanley Elementary is 250 South Street Waltham Ma 02453.**

**Q2. What is the quantity of glycol in each school?**

**A2. Kennedy = 5,000 gallons, Stanley = 3,500 gallons**

**End of Addendum 2**