

THE CITY OF WALTHAM
MASSACHUSETTS
PURCHASING DEPARTMENT

Gymnasium and Auditorium Renovations, South Middle School

ADDENDUM NO. 2

Nov. 4, 2011

CHANGES, CORRECTIONS AND CLARIFICATIONS

The attention of bidders submitting proposals for the above subject project is called to the following addendum to the specifications. The items set forth herein, whether of omission, addition, substitution or clarification are all to be included in and form a part of the proposal submitted.

THE NUMBER OF THIS ADDENDUM (NO. 2) MUST BE ENTERED IN SECTION 'A' OF THE FORM FOR GENERAL BID AND FILE SUB BID.

ITEM NO.: 1 ANSWERS TO POSED QUESTIONS

QUESTIONS:

1. What kind of paint do you require for the gym CMU walls?
Latex or Epoxy?
2. What kind of paint do you require for the exposed gym ceiling structure and metal deck? We recommend a spray applied latex "dryfall."
3. What kind of paint do you require for the window frames and other wood elements?
4. What kind of paint do you require for the metal railings and guardrails?

ANSWERS:

Drywall/ Plaster/ Wood

1. Primer for drywall surface to be Benjamin Moore Fresh Start (024), or equal.
2. Finish coats shall be Impervo Alkyd High Gloss Metal and Wood Enamel (133), or equal.

CMU Walls

1. Moorecraft Super Craft Latex Block Filler (285) primer, or equal. Apply (2) coats to fill all the voids in the block finish.
2. Two (2) finish coats shall be I.M.C. Urethane Alkyd Gloss Enamel (M22) in High Gloss finish, or equal.

Metal

1. Metal surfaces to be primed with Iron Clad Alkyd Low Luster Metal and Wood Enamel (163), or equal.
2. Finish coats shall be Impervo Alkyd High Gloss Metal and Wood Enamel (133), or equal.

Exposed Gym Ceiling and Metal Deck

1. Benjamin Moore Super Spec® sweep-up latex semi-gloss 156, or equal.