

THE CITY OF WALTHAM  
MASSACHUSETTS

PURCHASING DEPARTMENT  
**DESIGN, MacArthur Elementary School  
Playground Improvements**

**ADDENDUM NO. 2**

November 10, 2016

**CHANGES, CORRECTIONS AND CLARIFICATIONS**

The attention of bidders submitting proposals for the above subject project is called to the following addendum to the specifications. The items set forth herein, whether of omission, addition, substitution or clarification are all to be included in and form a part of the proposal submitted.

THE NUMBER OF THIS ADDENDUM (NO. 2) MUST BE ACKNOWLEDGED AS RECEIVED IN THE PRICE SHEET

---

**ITEM 1: ANSWERS TO POSED QUESTIONS**

QUESTION 1. It is our understanding that any increase in impermeable paving greater than 150 square feet, such as rubber surfacing, would require under City of Waltham regulations, infiltration of this additional run-off on-site (typically subsurface), with an engineering I & I permit application stamped by a Civil Engineer with drainage calculations. In order to have a consistency of services included in the proposal, can you address this issue, as to whether Civil Engineering services need to be included.

**ANSWER:** Yes Civil engineering services need to be included in your service. The I & I calculation is for any discharge from the proposed park improvement project that would be discharge to the sewer collection system of the City. This is typically calculated by using the MassDEP title 5. With respect to the drainage design, Engineering believes what is written in terms of recharge of the additional runoff is accurate.

**End of Addendum 2**