

THE CITY OF WALTHAM  
MASSACHUSETTS  
PURCHASING DEPARTMENT  
**School St. & Lexington St. Sanitary Sewer & Water Main Improvements**

**ADDENDUM NO. 2**

April 16, 2019

**CHANGES, CORRECTIONS AND CLARIFICATIONS**

The attention of bidders submitting proposals for the above subject project is called to the following addendum to the specifications. The items set forth herein, whether of omission, addition, substitution or clarification are all to be included in and form a part of the proposal submitted.

THE NUMBER OF THIS ADDENDUM (NO. 2) MUST BE ACKNOWLEDGED ON YOUR COVER SHEET.

---

**ITEM 1: ANSWERS TO POSED QUESTIONS**

**Q1.** There is a discrepancy in the contract documents where the plans call for class 52 Ductile Iron Pipe and the specs call for Class 56 Ductile Iron Pipe. What type of pipe are required for the project?

**A1.** The Class of the water main pipe is Class 56 Ductile Iron Pipe.

**End of Addendum 2**