

THE CITY OF WALTHAM
MASSACHUSETTS

PURCHASING DEPARTMENT

Embassy Parking Garage Renovations, 2024

ADDENDUM NO. 3

April 2, 2024

CHANGES, CORRECTIONS AND CLARIFICATIONS

The attention of bidders submitting proposals for the above subject project is called to the following addendum to the specifications. The items set forth herein, whether of omission, addition, substitution, or clarification are all to be included in and form a part of the proposal submitted. THE NUMBER OF THIS ADDENDUM (NO. 3) MUST BE ACKNOWLEDGED IN THE FORM FOR GENERAL BID, FORM FOR FILED SUB BID, SECTION 00 60 01 AND/OR SECTION 00 60 02.

ITEM 1: Answers to Posed Questions

Q1. During the walkthrough I believe Jibreel from Socotec mentioned washing the existing concrete walls and applying a waterproof sealer. I don't see that on the drawings, can you confirm if that is or isn't included?

A1. The exterior concrete perimeter walls on the upper level, lower level, and the inner side of the ramp spandrel are to have the surfaces cleaned and dried prior to installing the anti-graffiti coating per detail 14 & 15/S3-02. This will be completed by the Waterproofing Filed Sub Bidder. Please refer to the Specification Section 01 11 13 Summary of Work Section 1.03H and Section 07 19 19 Silicone Water And Graffiti-Resistant Treatments for additional information.

END OF ADDENDUM NO. 3