

THE CITY OF WALTHAM
MASSACHUSETTS

PURCHASING DEPARTMENT

Jennings Road Sewer Replacement and Drain Rehabilitation, 2021

ADDENDUM NO. 3

September 30th, 2021

CHANGES, CORRECTIONS AND CLARIFICATIONS

The attention of bidders submitting proposals for the above subject project is called to the following addendum to the specifications. The items set forth herein, whether of omission, addition, substitution or clarification are all to be included in and form a part of the proposal submitted.

THE NUMBER OF THIS ADDENDUM (NO. 3) MUST BE ACKNOWLEDGED ON YOUR PRICE SHEET.

ITEM 1: Answers to Posed Questions:

Q1. Could you please confirm the locations of work covered under item 4b. Estimated quantities appear to have been overstated.

A1. The Quantity stated under Item 4B – 15” RCP Drain was increased to cover potential necessary repairs identified through investigations completed under Item 25 – Smoke & Dye Testing and Item 27 – CCTV Inspection of Sewer & Drain. The quantity paid for under Item 4B shall be the actual number of linear feet of 15” RCP drain pipe furnished, installed, and accepted.

Q2. It is not clear as to the location for work covered under items #7 & #16b. Can you please confirm where the 6” water main relocation and new granite curbing is to take place.

A2. Item 7 – Relocation of 6” Water Main shall be used as directed by the Engineer when relocation of the existing water main is deemed necessary to complete the proper installation of proposed sewer and drain improvements as shown in the Contract Documents.

Item 16B – New Granite Curbing shall be used to replace existing curbing within the project area that, in the opinion of the Engineer is damaged and must be replaced.

End of Addendum 3