

THE CITY OF WALTHAM
MASSACHUSETTS
PURCHASING DEPARTMENT

Trapelo Road Water Services, 2018

ADDENDUM NO. 3

December 12th, 2018

CHANGES, CORRECTIONS AND CLARIFICATIONS

The attention of bidders submitting proposals for the above subject project is called to the following addendum to the specifications. The items set forth herein, whether of omission, addition, substitution or clarification are all to be included in and form a part of the proposal submitted.

THE NUMBER OF THIS ADDENDUM (NO. 1) MUST BE ACKNOWLEDGED IN SECTION Bid Price Form Page.

ITEM 1: ANSWERS TO POSED QUESTIONS

- Q1.** When replacing the hydrants, is the contractor to use the existing tee or install a new tee for the hydrant lateral?
A1. *No it is not anticipated that the contractor will need to replace tee's for hydrant laterals*
- Q2.** Will inserted tees be acceptable when tying in sewer laterals to the main line sewer or must PVC tees be used for the tie-in?
A2. *Inserta Tee's would be acceptable if the sewer main is in good enough condition for the Inserta tee to be used*
- Q3.** Are water and sewer services being replaced to the property line or to the building?
A3. *Water & sewer services are being replaced to the property line*
- Q4.** Does page 00100-8 need to be signed and submitted with the bid?
A4. *YES*
- Q5.** Does Section 00300 just consist of the two bid price sheets? If not, can the City please provide the complete Section 00300 FORMS FOR GENERAL BID?
A5. *This section is only 2 pages.*
- Q6.** Section 00200 REQUIRED FORMS states that Contractor's Affirmative Action Plan and Contractor's Equal Opportunity Statement must be submitted with the bid. However, these forms are not supplied in the bid documents. Can the City please provide these forms?
A6. *Submit your plan on your own form*
- Q7.** Section 00316 STATEMENT OF BIDDER'S QUALIFICATIONS has a questions (Questions 6 & 16) asking about the bidder's experience pertaining to manhole rehabilitations. Can the City please clarify if this questions must be answered in regards to this project, seeing that this project is water and sewer service improvements and not the rehabilitation of manholes?
A7. *Ignore this language*

End of Addendum 3