

THE CITY OF WALTHAM
MASSACHUSETTS

PURCHASING DEPARTMENT

Cornelia Warren Park Improvements, 2019

ADDENDUM NO. 5

May 29th, 2019

CHANGES, CORRECTIONS AND CLARIFICATIONS

The attention of bidders submitting proposals for the above subject project is called to the following addendum to the specifications. The items set forth herein, whether of omission, addition, substitution or clarification are all to be included in and form a part of the proposal submitted.

THE NUMBER OF THIS ADDENDUM (NO. 5) MUST BE ACKNOWLEDGED ON YOUR FORM FOR GENERAL BID PAGE.

ITEM 1: DELETE AND REPLACE

On pg 147 of the RFB, SECTION 321813 - SYNTHETIC GRASS SURFACING, Paragraph 1.9 Warranty, A.2, **DELETE** 12 years and **REPLACE** with 8 years.

ITEM 2: ANSWERS TO POSED QUESTIONS:

Q1. What is the detail for Outlet Control Structures?

A1. Outlet Control Structures shall be the same as the Area Drain Detail, utilizing a PVC drain basin. Outlet Control Structures shall have a cast iron frame and cover, whereas the Area Drains shall have a cast iron frame and grate

End of Addendum 5

