

THE CITY OF WALTHAM
MASSACHUSETTS

PURCHASING DEPARTMENT

Generator and Maintenance Service, 2019

ADDENDUM NO. 5

May 9th, 2019

CHANGES, CORRECTIONS AND CLARIFICATIONS

The attention of bidders submitting proposals for the above subject project is called to the following addendum to the specifications. The items set forth herein, whether of omission, addition, substitution or clarification are all to be included in and form a part of the proposal submitted.

THE NUMBER OF THIS ADDENDUM (NO. 5) MUST BE ACKNOWLEDGED ON YOUR COVER SHEET

ITEM 1: ANSWERS TO QUESTIONS

Q1. You are requesting a change out of spark plugs, points and condenser on a semi-annual basis. This would be twice a year, for a generator which will average about 30 hours of use in total for the year. Most platinum spark plugs are good for 500 hours. Therefore; it might be better to change to bi-annual (every other year).

A1. Change to bi-annual (every other year).

End of Addendum 5